

Corrigendum-etender for Supply, Installation of 20 KVA UPS (Parallell)

Tender Reference No: CFTRI/A3/79309/2019-20

Tender ID: 2019_CSIR_37148_1

Tender Title: Supply, Installation of 20 KVA UPS

Corrigendum Title: Corrigendum to specification (additional information-specification)/
Extension of date for submission of bid

Corrigendum Type: Before tender opening

Additional information/clarification

Clarification sought by one of the firm	Additional information/clarification
Is the price bid asked for 1 No of 20 KVA UPS	1 Unit – 2 x 20 KVA UPS with individual battery bank (separate for each UPS) in parallel to be supplied along with vertical stacking battery stands.
Control panel	Control panel display should be on the front side of UPS
Battery: Type: 12V quanta SMF: VAH Rating,Min. 31000 vah for each battery bank: 12 V, 100AH-28 Nos, Battery bank with metal racks-Vertical and interlink cables	Any quanta battery combination which gives 1 hour back up with full load is acceptable i.e. 31000 VAH for 28 Nos OR equivalent, , Battery bank with metal racks-Vertical and interlink cables
Input/output wiring	Input/Output wiring will be done internally

All other specification and Terms & Conditions of tender remains unaltered except for the following:

The last date for submission of bid stands extended up to 23rd December 2019 upto 2.00 P.M

Bid opening (Technical) on line in etender.gov.in : 24th December 2019 at 2.30 P.M

Bidders are requested to note above extension of date for bid submission and accordingly submit your offer with relevant documents .

Approved by


Signature 16/12/19 .

Dt. 16.12.2019